

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 138

Dated: 09.10.2026

It is certified that an inspection team headed by Dr. Amit yede

(Name of Officers with designation) from Medical Officer R.H. Deori PHED

inspected the C.S. English public school, Deori

(Name & Address of the school) on 05.10.2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. DLNN-0261009/01 dated 09/10/2026

of M.S. Dist. Laboratories Gondia (PHED Lab) certified that the

C.S. English public school Deori (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 01 year

Signature with Seal: [Signature]

Name

Designation

Name & Address of the Office / Department: R.H. Deori

Medical Officer
Rural Hospital Deori
Dist. Gondia

To C.S. English public
school, Deori

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

[Signature]
Manager

C.S. English Public School,
Deori



[Signature]
Principal

C.S. English Public School
Deori Dist.-Gondia

M.S. DIST. LABORATORIES

(OPC) PVT. LTD. | MATERIAL TESTING LABORATORY
TECHNOLOGY AND RESEARCH | CONFORMITY ASSESSMENT BODY
CIN: U71200MH2024OPC434418 | REG AD : PLOT NO.37, RAILTOLI, GONDIA (M.S.) - 441614

☎ : +91-9834076810
✉ : DIRECTOR@DLG.IND.IN

Doc. No. MSDL/05/7.8.2

TEST REPORT

Page 1 of 1

Test Report No.		DLNN-0261009/01		
Report Date:		Dt. 09/10/2026		
*Name & Address of Customer		C.S. English Public School, Deori (CBSE) Shivaji Campus, Chichgad Road, Deori Dist - Gondia (M.S.) - 441901		
*Name of Project		Testing of Drinking Water		
Customer Ref. Letter No. & Date		No. 653 Dt. 05/10/2026		
Identification of Test Item (Lab ID No.)		SRF No. NN-0261005/01		
Sample (a) Description		Water		
(b) Quantity		5 Litres	Source	NA
(c) Condition		Good	Make/ Grade of Sample	NA
(d) Date of receipt of sample		05/10/2026	Packing when received	Sealed
Date of Testing	a) Start Date	07/10/2026	Temperature °C	25
	b) End Date	08/10/2026	Humidity %	45
Discipline		Chemical	Group	Water

The results of the test conducted on received samples are as follows:

WATER:

Sr. No.	Test Parameter	UOM	Test Method	Test Result	Requirement as per IS 10500 : 2012
1	pH Value	-	IS 3025 (P11) : 2022	6.96	6.5 - 8.5
2	Colour	Hazen	IS 3025 (P4) CL-4 : 2021	Less than 5	15 Max.
3	Odour	-	IS 3025 (P5) : 2018	Agreeable	Agreeable
4	Turbidity	NTU	IS 3025 (P10) : 2023	0.1	1 Max.
5	Free Residual Chlorine as CL	mg/l	IS 3025 (P26) CL-5 : 2021	Not Detectable	0.2 Min. (To be applicable only when water is chlorinated)
6	Chloride as CL	mg/l	IS 3025 (P32) CL-6 : 2025	60.1	250 Max.
7	Sulphate as SO ₄	mg/l	IS 3025 (P24)/Sec-1 CL-4.5 : 2022	36.2	200 Max.
8	Flouride as F	mg/l	APHA 24 th Edition/4500 - FD : 2023	0.2	1.0 Max.
9	Iron as Fe	mg/l	IS 3025 (P53), CL-6 : 2024	Not Detectable	0.30 Max.
10	Total Hardness as CaCO ₃	mg/l	IS 3025 (P21) : 2009	53	200 Max.
11	Total Alkalinity as CaCO ₃	mg/l	IS 3025 (P23) : 2023	45	200 Max.
12	Calcium as Ca	mg/l	APHA 24 th Edition/3500 Ca-B : 2023	16.2	75 Max.
13	Magnesium as Mg	mg/l	APHA 24 th Edition/3500 Mg-B : 2023	8.5	30 Max.
14	Total Dissolve Solids	mg/l	IS 3025 (P16) : 2023	193	500 Max.

*Remark (if any): *Data provided by client

Note: 1. This test report refers only to the sample submitted for testing by the client; sampling is not done by the Lab.


2. Conformity Statement: **NA**. 3. Addition to, Deviation, or exclusion from the test method: **NA**4. Results provided by the external service provider: **YES**

5. Publication or reproduction of this report in any form other than by complete set of the whole report and in the language written, is not permitted without the written approval of Lab Director.

6. Samples may be destroyed/ removed from laboratory after testing, unless otherwise particular request is made.

7. Any correction/ erasing invalidates this test report. 8. All disputes are subject to Gondia Jurisdiction only.

Reviewed By



Ms. R.M. Balge


Manager
C.S.English Public School,
Deori

Principal
C. S. English Public School
Deori Dist.-Gondia

For, M.S. Dist. Laboratories

(OPC) Pvt. Ltd.


Mr. K.N. Agrawal
Authorized Signatory
(Managing Director)